CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: T- 5548

Format No: CP/TF/01

TEST REPORT ON BITUMEN

Lab ID	:	**CP-2017-11-22-04** **Date: 25-11-2017**
Customer	:	Assistant Executive Engineer, Yelahanka Satellite town Sub Division, BBMP, Bangalore.
Address	:	Yelahanka Satellite town Sub Division, BBMP, Bangalore.
Agency	:	Sri.B.B Umesh, SMLP Asphalts, Bettahalasoor V & Post, Bangalore North.
Project Name	:	Providing pot hole filling in ward No.04.
Customer's Reference	:	BBMP/EE(YNK.D)/W.O/118/2016-17
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	22-11-2017
Sample ID No	:	2017-11-22-04/01
Sample Type	:	Bitumen
Reference to BIS codes	:	IS: 1201-1220(1978) (Reaffirmed-2004)
Date of test	:	23-11-2017

Test Results

Sl.no	Name of Test	Result	Requirements as per IS:73-2013
1	Penetration at 25°C , in 1/10th mm	**65**	60 to 70
2	Softening Point, °C	**43.6**	Min. 40°C
3	Ductility, cm	**88**	Min. 75cm
4	Flash point, °C	**238**	Min. 220°C
	Fire point, °C	**255**	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

AE W4

FOR CIVIL Pro.

CIVIL Pro Sig..... Date.....

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com